


Dorsch Holding GmbH  
DC Abu Dhabi  
Salam Street  
P.O. Box 26 417  
Abu Dhabi  
United Arab Emirates

Phone : +971 2 672 19 23  
Fax : +971 2 672 08 09  
E-Mail : info@dorsch.ae  
Internet : www.dorsch.de

Head office: Offenbach, Germany  
Trade reg. Offenbach a.M. No. HRB 42115  
VAT No. DE247139650  
Managing Directors:  
Dipl.-Ing. Jürgen Röder  
Dipl.-Ing. Olaf Hoffmann  
Andreas Rienecker  
Dipl.-Ing. Andrea Pal



M/s. Al Ryum Cont.& Tran. Est  
P.O. BOX : 28427  
ABU DHABI, UAE

4100 / 9793/ 10  
6721923-131

arahim@dorsch.de

02 Aug 2010

**Ref: PRFD Contract 4100**  
**Irrogation & Landscaping Works at Yas Island Interchange,**  
**Abu Dhabi – Dubai Road**

**Sub.: Material Submittal: Artificial Grass**

**Artificial Turf Grass – XL Turf**  
**From XL Turf AG Switzerland**

Dear Sirs,

Referring to your submittal vide ref: C4100/037/MAR/2010/AT dated August 02, 2010, requesting review and approval of the subject for the ref. Contract.

Basis of the submitted documents and sample reviews, M/s. XL Turf artificial turf has found provisionally acceptable to purport the landscape applications for the reference Contract. Whereas here you are required to attend the following,

1. Subject turf materials performance objectives might be satisfied and its aesthetics value, reliability on function, etc. shall be adhered with manufacturer guarantee. However, here we accepting to proceed with subject turf application and please note that final appearance / performance criteria must be satisfied / to be loyal with the manufacturer clarifications while the time final inspection.
2. Please provide a representative sample (with a pile length of 35mm) of atleast 2" x 2" in size.
3. Turf system must look natural in terms of color, fiber texture and in feel as well. Prepare a demonstration with the proposed artificial turf pattern against natural turf to compare its texture.
4. Installation method statement must be submitted. Fixing accessories and its material data shall be submitted for Engineers review.
5. Authorised warantee statement of manufacturer must be obtained.
6. Maintanance methodology and its period of responsibility held on are to be responded.

7. Client / Consultant Engineers representative's technical appraisal visit to the manufacturer premises shall be arranged for,


- Production witness of proposed consignment
- Sampling and testing
- To appraise the plant QC
- To appraise similar installations, etc.

Readiness and its schedule proposal are to be informed.

Promptly for your information and necessary further actions, we remain.



Abdul Rahim Kaladi  
Head of Materials & QA/QC



Ayman Heikal  
Chief Operations Officer

CC: Director, PRFD , Head of Construction, PRFD  
Eng. Mohd. Ali Al Jafry, Head of Materials and QA/QC, PRFD  
DC-File, Site RE, MOU,KAB, RAH